

FPL Residential A/C Rebate Schedules

Effective Date: January 2008

Residential Straight Cool FPL Rebates (Air-Cooled Equipment)

| SIZE OR COOLING CAPACITY IN: | SEER EFFICIENCY RATING | | | | | | | |
|------------------------------|------------------------|-------------|-------------|-------------|-------------|-------------|-----------|---------|
| BTUh* | From-To | 14.0 - 14.9 | 15.0 - 15.9 | 16.0 - 16.9 | 17.0 - 17.9 | 18.0 - 18.9 | 19.0-19.9 | 20.0 + |
| <21,000 | <2T | \$125 | \$220 | \$305 | \$390 | \$445 | \$500 | \$570 |
| 21,000 - 26,999 | 2.0T | \$140 | \$265 | \$405 | \$515 | \$585 | \$670 | \$755 |
| 27,000 - 32,999 | 2.5T | \$165 | \$320 | \$500 | \$640 | \$740 | \$840 | \$950 |
| 33,000 - 38,999 | 3.0T | \$210 | \$375 | \$585 | \$770 | \$880 | \$1,005 | \$1,130 |
| 39,000 - 44,999 | 3.5T | \$265 | \$475 | \$685 | \$895 | \$1,035 | \$1,175 | \$1,330 |
| 45,000 - 50,999 | 4.0T | \$305 | \$545 | \$780 | \$1,020 | \$1,175 | \$1,340 | \$1,510 |
| 51,000 - 56,999 | 4.5T | \$375 | \$640 | \$895 | \$1,145 | \$1,330 | \$1,510 | \$1,705 |
| 57,000 - 65,000 | 5.0T | \$430 | \$725 | \$1,005 | \$1,285 | \$1,495 | \$1,705 | \$1,930 |
| BTUh* | EER EFFICIENCY RATING | | | | | | | |
| | From-To | 11.0 -11.9 | 12.0 -12.9 | 13.0 -13.9 | 14.0 -14.9 | 15.0 -15.9 | 16.0-16.9 | 17.0 + |
| >65,000 | | \$630 | \$975 | \$1,185 | \$1,375 | \$1,650 | \$1,900 | \$2,100 |

Residential Heat Pump FPL Rebates (Air-Cooled Equipment)

| SIZE OR COOLING CAPACITY IN: | SEER EFFICIENCY RATING | | | | | | | |
|------------------------------|------------------------|-------------|-------------|-------------|-------------|-------------|-----------|---------|
| BTUh* | From-To | 14.0 - 14.9 | 15.0 - 15.9 | 16.0 - 16.9 | 17.0 - 17.9 | 18.0 - 18.9 | 19.0-19.9 | 20.0 + |
| <21,000 | <2T | \$125 | \$220 | \$305 | \$390 | \$445 | \$500 | \$570 |
| 21,000 - 26,999 | 2.0T | \$140 | \$265 | \$405 | \$515 | \$585 | \$670 | \$755 |
| 27,000 - 32,999 | 2.5T | \$165 | \$320 | \$500 | \$640 | \$740 | \$840 | \$950 |
| 33,000 - 38,999 | 3.0T | \$210 | \$375 | \$585 | \$770 | \$880 | \$1,005 | \$1,130 |
| 39,000 - 44,999 | 3.5T | \$265 | \$475 | \$685 | \$895 | \$1,035 | \$1,175 | \$1,330 |
| 45,000 - 50,999 | 4.0T | \$305 | \$545 | \$780 | \$1,020 | \$1,175 | \$1,340 | \$1,510 |
| 51,000 - 56,999 | 4.5T | \$375 | \$640 | \$895 | \$1,145 | \$1,330 | \$1,510 | \$1,705 |
| 57,000 - 65,000 | 5.0T | \$430 | \$725 | \$1,005 | \$1,285 | \$1,495 | \$1,705 | \$1,930 |
| BTUh* | EER EFFICIENCY RATING | | | | | | | |
| | From-To | 11.0 -11.9 | 12.0 -12.9 | 13.0 -13.9 | 14.0 -14.9 | 15.0 -15.9 | 16.0-16.9 | 17.0 + |
| >65,000 | | \$630 | \$975 | \$1,185 | \$1,375 | \$1,650 | \$1,900 | \$2,100 |

Residential Straight Cool & Heat Pump (Water Source)

| SIZE OR COOLING CAPACITY IN: | EER EFFICIENCY RATING | | | | | | |
|------------------------------|-----------------------|-------------|-------------|-------------|-------------|-------------|---------|
| BTUh* | 13.0 - 13.9 | 14.0 - 14.9 | 15.0 - 15.9 | 16.0 - 16.9 | 17.0 - 17.9 | 18.0 - 18.9 | 19.0 + |
| <15,000 | \$50 | \$85 | \$115 | \$140 | \$160 | \$180 | \$200 |
| 15,000 - 20,999 | \$80 | \$130 | \$170 | \$210 | \$240 | \$270 | \$295 |
| 21,000 - 26,999 | \$110 | \$170 | \$230 | \$285 | \$325 | \$360 | \$395 |
| 27,000 - 32,999 | \$135 | \$215 | \$280 | \$355 | \$400 | \$450 | \$495 |
| 33,000 - 38,999 | \$165 | \$265 | \$340 | \$425 | \$480 | \$540 | \$595 |
| 39,000 - 44,999 | \$190 | \$300 | \$400 | \$495 | \$565 | \$630 | \$690 |
| 45,000 - 50,999 | \$215 | \$350 | \$460 | \$565 | \$640 | \$720 | \$790 |
| 51,000 - 56,999 | \$245 | \$390 | \$520 | \$635 | \$730 | \$810 | \$890 |
| 57,000 - 65,000 | \$275 | \$430 | \$575 | \$705 | \$805 | \$910 | \$1,000 |
| >65,000 | \$400 | \$555 | \$700 | \$830 | \$930 | \$1,035 | \$1,125 |



FPL®

POWERING TODAY. EMPOWERING TOMORROW.®

*1 Ton = 12,000 BTUh

Annual Cooling Cost Comparison

Cooling Efficiency in SEER (Years produced)

| Size or cooling capacity in: | Cooling Efficiency in SEER (Years produced) | | | | | | | | | | | | | | | | | | |
|------------------------------|---|------------|-------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|--|--|--|--|--|--|--|
| A/C System (tons) | BTU/Hour | 9 (1980's) | 10 (1990's) | 11 | 12 | 13 | 14 | 15 | 16 | 17 | 18 | 19 | | | | | | | |
| 2 | 24,000 | \$900 | \$810 | \$730 | \$670 | \$620 | \$580 | \$540 | \$500 | \$470 | \$450 | \$420 | | | | | | | |
| 2.5 | 30,000 | \$1,120 | \$1,010 | \$920 | \$840 | \$780 | \$720 | \$670 | \$630 | \$590 | \$560 | \$530 | | | | | | | |
| 3 | 36,000 | \$1,340 | \$1,210 | \$1,100 | \$1,010 | \$930 | \$860 | \$810 | \$760 | \$710 | \$670 | \$640 | | | | | | | |
| 3.5 | 42,000 | \$1,570 | \$1,410 | \$1,280 | \$1,180 | \$1,090 | \$1,010 | \$940 | \$880 | \$830 | \$780 | \$740 | | | | | | | |
| 4 | 48,000 | \$1,790 | \$1,610 | \$1,470 | \$1,340 | \$1,240 | \$1,150 | \$1,080 | \$1,010 | \$950 | \$900 | \$850 | | | | | | | |
| 4.5 | 54,000 | \$2,020 | \$1,810 | \$1,650 | \$1,510 | \$1,400 | \$1,300 | \$1,210 | \$1,130 | \$1,070 | \$1,010 | \$950 | | | | | | | |
| 5 | 60,000 | \$2,240 | \$2,020 | \$1,830 | \$1,680 | \$1,550 | \$1,440 | \$1,340 | \$1,260 | \$1,190 | \$1,120 | \$1,060 | | | | | | | |

Example: Annual cooling cost to run a 3-ton (36,000 BTU/Hour) produced in the 1990s with a 10 SEER will be \$1,210. If replaced with a new 15 SEER system, the cost drops to \$810 - a savings of \$400 per year.
 Costs based on 2,800 annual cooling hours and 12 cents per kWh (average for South Florida)